

## Eligibility Checklist for Expedited Solar Photovoltaic Permitting for One- and Two-Family Dwellings

### GENERAL REQUIREMENTS

---

- |                                                                                          |                            |                            |
|------------------------------------------------------------------------------------------|----------------------------|----------------------------|
| A. County of Orange standard plan is used                                                | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. System size is 10 kW AC CEC rating or less                                            | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. The solar array is roof-mounted on one- or two-family dwelling or accessory structure | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. The solar panel/module arrays will not exceed the maximum legal building height       | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| E. Solar system is utility interactive and without battery storage                       | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| F. Permit application is completed and attached                                          | <input type="checkbox"/> Y | <input type="checkbox"/> N |

### ELECTRICAL REQUIREMENTS

---

- |                                                                                                                                                                          |                            |                            |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|----------------------------|
| A. No more than four photovoltaic module strings are connected to each Maximum Power Point Tracking (MPPT) input where source circuit fusing is included in the inverter | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 1) No more than two strings per MPPT input where source circuit fusing is not included                                                                                   | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 2) Fuses (if needed) are rated to the series fuse rating of the PV module                                                                                                | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| 3) No more than one noninverter-integrated DC combiner is utilized per inverter                                                                                          | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. For central inverter systems: no more than two inverters are utilized                                                                                                 | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. The PV system is interconnected to a single-phase AC service panel of nominal 120/220 Vac with a bus bar rating of 225 A or less                                      | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. The PV system is connected to the load side of the utility distribution equipment                                                                                     | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| E. A Solar PV Standard Plan and supporting documentation is completed and attached                                                                                       | <input type="checkbox"/> Y | <input type="checkbox"/> N |

### STRUCTURAL REQUIREMENTS

---

- |                                                                             |                            |                            |
|-----------------------------------------------------------------------------|----------------------------|----------------------------|
| A. A completed Structural Criteria and Supporting documentation is attached | <input type="checkbox"/> Y | <input type="checkbox"/> N |
|-----------------------------------------------------------------------------|----------------------------|----------------------------|

### FIRE SAFETY REQUIREMENTS

---

- |                                                                                                                                                                                            |                            |                            |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------|----------------------------|
| A. Clear access pathways provided                                                                                                                                                          | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| B. Fire classification solar system is provided                                                                                                                                            | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| C. All required markings and labels are provided                                                                                                                                           | <input type="checkbox"/> Y | <input type="checkbox"/> N |
| D. A diagram of the roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points is completed and attached | <input type="checkbox"/> Y | <input type="checkbox"/> N |

- Notes:
- These criteria are intended for expedited solar permitting process.
  - A "YES" or "NO" must be attached for all items. If any item is not checked "YES", revise design to within this Eligibility Checklist, otherwise permit application must go through standard process of 5 working days.